arXiv:1101.1118v4 [cs.CE] 14 Feb 2011

Towards Decentralized Trading: A Topological Investigation of the Dutch Medium and Low Voltage Grids

Giuliano Andrea Pagani and Marco Aiello

Distributed Systems Group
Johann Bernoulli Institute for Mathematics and Computer Science
University of Groningen
Groningen, The Netherlands

email: {g.a.pagani,m.aiello}@rug.nl
http://www.cs.rug.nl/ds/

February 15, 2011

Abstract

The traditional Power Grid has been designed in a hierarchical fashion, with energy pushed from the large scale production factories towards the end users. With the increasing availability of micro and medium scale generating facilities, the situation is changing. Many end users can now produce energy and share it over the Power Grid. Of course, end users need incentives to do so and want to act in an open decentralized energy market. In the present work, we offer a novel analysis of the Medium and Low Voltage Power Grids of the North Netherlands using statistical tools from the Complex Network Analysis field. We use a weighted model based on actual Grid data and propose a set of statistical measures to evaluate the adequacy of the current infrastructure for a decentralized energy market. Further, we use the insight gained by the analysis to propose parameters that tie the statistical topological measures to economic factors that influence the attractiveness of participating in such decentralized energy market, thus identifying the important topological parameters to work on to facilitate such open decentralized markets.

Keywords: Power Grid, Decentralized energy trading, Complex Network Analysis

1 Introduction

The Power Grid is one of the engineering masterpieces of the XIX-XX century, being one of the most important infrastructures that contributes to the economic growth and welfare of any country. It has been designed as a hierarchical system with large generating facilities on top, and a pervasive network of cables to distribute the energy to the geographically dislocated end users. Traditionally, it has been created to be managed by a monopolist or an oligarchy

of actors. Typically, energy availability is given for granted, though its importance becomes well too apparent both at the household and country level when prolonged blackouts strike and electricity flow is interrupted [1, 2].

Something is though changing in the way energy is produced and distributed due to both technological advancements and the introduction of new policies. A clear trend of market unbundling is emerging (e.g., [3, 4]) entailing the addition of many new players to the energy sector with the possibility to produce, sell and distribute energy. From the technological perspective, new energy generation facilities (mainly based on renewable sources) are becoming widely accessible. These are convenient and available at both the industrial and the residential scale [5, 6]. The term *Smart Grid*, which does not yet have a unique agreed definition, is sometimes used to define the new scenario of a Grid with a high degree of delocalization in the production and trading of energy. The new actors, who are both producers and consumers of energy, referred to as *prosumers*, are becoming more numerous and will most likely demand a market with total freedom to energy trading [7]. In this coming scenario the main role of the High Voltage Grid may change, while the Distribution Grid (i.e., Medium Voltage and Low Voltage end of the Power Grid) gain more and more importance, while requiring a major update. In fact, the energy interactions between prosumers will increase and most likely occur at a rather local level, therefore involving the Low and Medium Voltage Grids.

Given such emerging scenario, we propose to look at the lower layers of the Power Grid in a statistical manner, considering global metrics coming from the field of Complex Network Analysis. Few such studies exist in the literature using unweighted models of the High Voltage Grids. These have been performed especially to establish the resilience to failures of critical national infrastructures. It will not surprise that often such studies have appeared immediately after a major national blackout. More recently, these techniques have also been used for generating tests for the Smart Grid in [8]. Here we propose a novel study of the properties of the Medium and Low Voltage networks using the Northern part of the Netherlands as data source. Our investigation goes beyond the study of the existing as it also proposes a way of evaluating the infrastructure in terms of its ability to support delocalized energy trading. We argue that global topological statistical measures do influence the eagerness of prosumers to trade energy, which in turn, entails a structural modification of the Power Grid.

The paper is organized as follows. Motivation for the present study and an initial overview of the state of the art are presented in Section 2. In Section 3, we introduce the data set used for the study and provide essential definitions. In Section 4 we provide an initial unweighted Complex Network Analysis. Section 5 is dedicated to a weighted Complex Network Analysis which provides the best insight on the available sample and a set of novel measures in the statistical study of the Power Grid. A comparison with an unweighted Complex Network Analysis is provided Section 6. The proposal on how to tie topological metrics to economic factors is presented in Section 7, together with an example. A detailed account of related work on Complex Network Analysis for the (High Voltage) Power Grid is provided in Section 8. Final discussion and conclusions are offered in Section 9.

2 A Statistical View on the Power Grid

Many scientific knowledge areas contribute to the design and analysis of Power systems: Physics (electromagnetism, classical mechanics), Electrical engineering (AC circuits and phasors, 3-phase networks, electrical systems control theory) and Mathematics (linear algebra, differential equations). Such traditional studies tend to have a "local" view of the Grid, e.g., defining how to design a transformer and predicting its functioning. Typically studies tend to focus on the physical and electrical properties (e.g., [9]), or the characteristics of the Power Grid as a complex dynamical system [10], or again, the control theory aspects [11].

The move from a "local" to a "global" view of the Power Grid as a complex system is possible by resorting to statistical graph theory, better known as *Complex Network Analysis (CNA)*, that is, a statistical analysis of the dynamics of large graphs with the goal of identifying their characterizing properties, such as the average path length between any two nodes. Studies of this sort have been recently performed for example on the American [12, 13], the Italian [14], and the Scandinavian [15] Grids; the European Grid as a whole is analysed in [16, 17]. Interestingly, these studies, though using the same mathematical machinery, reach different conclusions on the characteristics of the identified graph (e.g., node degree distribution, network category). An explanation for this is that different geographical infrastructures may indeed have different layouts, thus yielding different topological properties.

Motivations for such CNAs are common to all previous researches and are mainly two: identifying the right complex network model for the Power Grid; and provide a resilience analysis for predicting blackouts and critical components of the infrastructure. Folkloristic is that Power Grid CNA studies are 'popular' after a major blackout occurs, such as the North American black-out of 2003[1] or the Italian one of 2003[2] (e.g., [13, 18, 14, 12]). The fragility of the Power Grid has been the major reason of concern that has determined the focus of such CNA studies on the High Voltage. In fact, High Voltage failures impact a large part of the network, thus resulting in electricity service disruptions of large portions of a whole country. From a graph perspective, the High Voltage samples for an entire country are usually quite small in terms of order and size. For instance, the Grids connecting the 15 European countries analysed by Rosas-Casals *et al.* in [17] are composed overall of about 2700 nodes and more than half of the analysed samples are below 100 nodes; moreover, the graphs studied in [19, 20] are well below 200 both nodes and edges, while the sample analysed in [14] has less than 400 nodes and a little more than 500 edges.

The motivation for the current work is quite different from previous approaches. We consider the Power Grid as an infrastructure for decentralized energy exchange. To this end, we are interested in the properties of the Medium and Low Voltages. Furthermore, we consider the Power Grid not only in its basic topology to assess resilience and connectivity, but also in the physical properties of the lines to assess the capacity of the infrastructure in supporting distribution. To the best of our knowledge, the study has novel motivations, in line with the current trends of the Smart Grid, but also studies new networks with novel weighted models.

[1] `http://news.bbc.co.uk/2/hi/americas/3152451.stm`
[2] `http://news.bbc.co.uk/2/hi/3146136.stm`

3 Northern Netherlands Medium and Low Voltage Complex Network Analysis

We focus on the Medium and Low Voltage Power Grid networks of (Northern) Netherlands. This choice is dictated by the fact that the Netherlands has a modern infrastructure. The Dutch High Voltage Power Grid is owned and managed by one player, Tennet, while the lower layers are partitioned geographically among fourteen companies[3] that have their own distribution network across the country. The partition of the territory among energy distribution companies is shown in Figure 1.

Figure 1: Distribution companies over the Netherlands. Each color corresponds to one company. *(Source: www.energieleveranciers.nl)*

The Grid information used in this study is provided courtesy of Enexis B.V., the distribution operator of Northern Netherlands. The provided data includes information about the transformers in the Grid together with the distribution substations. The data set also provides information about the distribution lines used to connect substations containing the length of cable and other interesting physical properties (e.g., resistance, capacity, voltage). For the sake of precision, we define the notion of a (Weighted) Power Grid graph.

- All the substations and transformers are considered equal and are represented as nodes of the graph.
- The cables connecting the substations are considered equal despite the differences in voltages and current carried and their physical properties, and thus modelled as unweighted edges in the graph.

[3]Zone identifier and distribution provider: 1) RENDO Netwerken, 2) Cogas Infra en Beheer, 3) Liander (former Continuon Netbeheer), 6) Stedin (former Eneco), 7) Westland Infra, 8) ONS Netbeheer (now Stedin), 9) DELTA Netwerkbedrijf, 12) NRE Netwerk, 13) Enexis (former Essent Netwerk), 14) InfraMosane (now Enexis).

	Present study						Random Graph		
ID	Order	Size	Avg. d	APL	CPL	γ	APL	CPL	γ
1	17	18	2.118	3.398	3.313	0.00000	1.427	1.688	0.13726
2	15	16	2.133	3.086	3.000	0.00000	2.319	2.358	0.00000
3	24	23	2.087	4.499	4.228	0.00000	3.127	3.091	0.05508
4	30	29	1.933	4.545	4.449	0.00000	1.860	2.242	0.05778
5	188	191	2.032	17.726	17.878	0.00000	3.846	4.345	0.00532
6	10	9	1.800	2.423	2.223	0.00000	0.978	1.167	0.26667
7	63	62	1.968	5.204	5.404	0.00000	2.514	2.904	0.03175
8	28	27	1.929	4.784	5.000	0.00000	2.553	2.945	0.04762
9	133	140	2.105	11.543	11.366	0.01112	3.702	4.172	0.01482
10	124	138	2.226	8.053	7.070	0.00869	3.010	3.540	0.02914
11	31	30	1.935	4.353	4.357	0.00000	1.590	1.969	0.07475

Table 1: Low Voltage samples from the northern Netherlands Power Grid compared with Random graphs of the same size.

- For the data samples that present disconnected components, each component is treated as a distinct graph.
- The edges are considered undirected.

These assumptions are common in Power Grid analysis from a graph theoretic perspective, see for instance [18, 16, 21, 19, 14, 15] and lead to the following definition.

Definition 1 (Power Grid graph)**.** *A* Power Grid graph *is a graph $G(V, E)$ such that each element $v_i \in V$ is either a substation, transformer, or consuming unit of a physical Power Grid. There is an edge $e_{i,j} = (v_i, v_j) \in E$ between two nodes if there is physical cable connecting directly the elements represented by v_i and v_j.*

The next step is to bring cable properties into the graph definition.

- For each cable connecting elements in the Grid a weight is defined based on the multiplication of the following quantities:
  - The principal resistance characterizing the cable (whose value is given in Ohm/km).
  - The length of the cable (whose value is given in km).
- A special kind of connection is defined in the Power Grid known as a 'link'. These are connections, usually very short, with negligible resistance for which the specific value is not provided in the dataset. For edges representing these links a conventional weight of 10^{-9} is given. This does not affect the overall validity of the weighted model since the number of links in a sample is extremely limited (about 1% of the overall connections are made of links).

Definition 2 (Weighted Power Grid graph)**.** *A* Weighted Power Grid graph *is a Power Grid graph $G_w(V, E)$ with an additional function $f : E \to \mathbb{R}$ associating*

a real number to an edge representing the resistance, expressed in Ohm, of the physical cable represented by the edge.

The analysis we perform uses samples from the Low Voltage and Medium Voltage Grids. The Low Voltage samples sum up to a total of 663 nodes and a 683 edges; while the Medium Voltage samples sum up to 4185 nodes and a 4574 edges. The size of the data set, tough being a sample and not the whole network, is about the same size or larger than those used in other available studies on the (High Voltage) Power Grid [21, 22, 14, 15, 17, 16, 19]. We begin our analysis by considering the unweighted model to derive basic topological properties and then proceed with a richer investigation by introducing graph weights.

	Present study						Random Graph		
ID	Order	Size	Avg. d	APL	CPL	γ	APL	CPL	γ
1	191	207	2.168	9.288	8.990	0.00296	4.616	5.079	0.00225
2	884	1059	2.396	9.817	9.527	0.00494	5.440	6.010	0.00170
3	444	486	2.189	11.033	10.858	0.00537	5.547	6.163	0.00333
4	472	506	2.144	17.095	17.174	0.01360	5.039	5.700	0.00106
5	238	245	2.059	11.715	11.580	0.00000	3.558	4.234	0.00595
6	263	288	2.190	12.775	12.311	0.01118	5.046	5.368	0.01080
7	217	229	2.111	10.321	10.241	0.00140	4.894	5.391	0.00121
8	366	382	2.087	15.113	14.546	0.00000	4.691	5.249	0.00405
9	218	232	2.128	10.850	10.915	0.00000	5.454	5.856	0.00539
10	201	204	2.030	15.742	15.257	0.00166	4.898	5.503	0.00491
11	202	213	2.109	13.504	12.891	0.00140	4.801	5.217	0.08750
12	25	24	1.920	5.781	5.500	0.00000	4.924	5.084	0.00000
13	464	499	2.151	13.144	12.703	0.00036	4.718	5.390	0.00209

Table 2: Medium Voltage samples from the northern Netherlands Power Grid compared with Random graphs of the same size.

4 Unweighted Power Grid study

The typical study of the Power Grid as a complex system considers High Voltage samples for identifying how fragile the infrastructure is. We use similar techniques for the Medium and Low voltage. Let us begin by recalling the basic complex network quantities.

Definition 3 (Adjacency, neighbourhood and degree)**.** *If $e_{x,y} \in E$ is an edge in graph G, then x and y are* adjacent, *or* neighbouring, *vertices, and the vertices x and y are* incident *with the edge $e_{x,y}$. The set of vertices adjacent to a vertex $x \in V$, called the* neighbourhood *of x, is denoted by $\Gamma(x)$. The number $d(x) = |\Gamma(x)|$ is the* degree *of x.*

A global measure for a graph is given by its average distance among any two nodes.

Definition 4 (Average path length (APL))**.** *Let $v_i \in V$ be a vertex in graph G,*

the average path length *for* G, L_{av} *is:*

$$L_{av} = \frac{1}{N \cdot (N-1)} \sum_{i \neq j} d(v_i, v_j)$$

where $d(v_i, v_j)$ *is the finite distance between* v_i *and* v_j *and* N *is the order of* G.

Definition 5 (Characteristic path length (CPL))**.** *Let* $v_i \in V$ *be a vertex in graph* G*, the* characteristic path length *for* G*,* L_{cp} *is defined as the median of* d_{v_i} *where:*

$$d_{v_i} = \frac{1}{(N-1)} \sum_{i \neq j} d(v_i, v_j)$$

is the mean of the distances connecting v_i *to any other vertex* v_j *in* G *and* N *is the order of the* G.

A measure of the average 'density' of the graph is given by the clustering coefficient, characterizing the extent to which vertices adjacent to any vertex v are adjacent to each other.

Definition 6 (Clustering coefficient (CC))**.** *The* clustering coefficient γ_v *of* Γ_v *is*

$$\gamma_v = \frac{|E(\Gamma_v)|}{\binom{k_v}{2}}$$

where $|E(\Gamma_v)|$ *is the number of edges in the neighbourhood of* v *and* $\binom{k_v}{2}$ *is the total number of possible edges in* Γ_v.

This local property of a node can be extended to an entire graph by averaging over all nodes of the graph.

4.1 Basic analysis

We now consider these classic measures on the data of the Dutch Power Grid. We divide our data set in samples of topologically connected regions. In Table 1, we report the basic analysis on the data modelled as an unweighted graphs and we compare each sample belonging to Low Voltage network with a random graph of the same size and order. The analysis for the Medium Voltage is reported in Table 2. Referring to the table, the first column is the ID of the sample, the second and third represent the number of vertices N (order) and edges M (size), respectively. The average degree (fourth column) is defined as $<k>= \frac{2M}{N}$. The fifth and sixth columns report the average and characteristic path lengths, that is the average of the minimum distance between any two given nodes and the median of the same quantities, respectively. The seventh column provides an indication of the clustering coefficient of the nodes, that is, broadly speaking, an average value of the power of a node to participate in connected aggregation with other nodes close to it.

We remark that the average node degree does not have highly different values in the Low and Medium Voltage samples, they are both around 2. Computing the mean over all samples' average node degree gives a value of $\overline{<k>} = 2.074$ with a very small variance $\sigma_{<k>} = 0.017$. This value appears to be almost

constant considering the Low Voltage and Medium Voltage samples since the variance of the two categories is even smaller ($\sigma_{<k>_{LV}} = 0.016$, $\sigma_{<k>_{MV}} = 0.012$). An almost constant average degree is also characteristic of the High Voltage Power Grid [16], though with a slightly higher value $<k>\cong 2.8$. This limited number of edges a node can manage can be regarded as a physical limit that each Power Grid substation has to satisfy.

Considering path measures: Average Path Length and Characteristic Path Length of the Low Voltage segment of the network have generally a smaller path length compared to the Medium Voltage one. The clustering coefficient is very small especially for the Low Voltage network for which many samples have a zero value (i.e., absence of triangles in the graph). The difference in path length between the Low Voltage and Medium Voltage is due to the higher number of nodes the Medium Voltage network samples have while holding the same average node degree as the Low Voltage, together with the absence of long distance edges. This implies a longer path to connect any two nodes in a bigger network. In addition, these values of APL and CPL are in general quite high, if compared to other networks such as the World Wide Web.

The clustering coefficients for the Low Voltage segment of the network are generally small; this is due to the strong hierarchical design of this layer of the physical network which resemble a tree-like structure. Contrarily, the Medium Voltage segment generally presents higher values for the clustering coefficient, this can be justified by the different purpose the Medium Voltage network has in which meshed components and connection redundancies are much more likely to be present for robustness reasons.

To gain an even better understanding of the tables just presented it is useful to compare the numbers obtained with those of Random graphs [23] and to identify the possible presence of *Small-world* properties. Small-world networks (SW), proposed by Watts and Strogatz in [21], own two important aspects at the same time: characteristic path length close in value to the one of a random graph (RG) ($CPL_{SW} \approx CPL_{RG}$) but a much higher clustering coefficient ($CC_{SW} \gg CC_{RG}$). Small-worlds are a better model than random graphs for social networks and other phenomena and thus a candidate for modelling the Power Grid too. To make the comparison genuine, random graphs are generated with the same number of nodes and edges as the real samples, imposing the resulting graphs not to have disconnected components. The values are presented on columns eight to ten of Tables 1 and 2. We note how the CPL of the Grid samples is on average twice as big as the random generated samples, thus comparable to as the definition of Small-world graph according to [21]. In addition the clustering coefficient of the Grid samples is almost always smaller than the result obtained for the random generated samples; this completely contradicts the definition of Small-world graph according to [21]. Watts and Strogatz [21] impose the following condition to the graphs they study: $N \gg k \gg ln(N) \gg 1$ where N is the number of nodes, k is the number of edges per node. Such a condition is not satisfied by the Northern Netherlands samples and generally it is not satisfied by Power Grid networks as pointed by Wang *et al.* in [8]. Interestingly, the same condition is also not satisfied by the Western States High Voltage Power Grid Watts and Strogatz use in [21] and Watts analyses in [24], while the results for CC and CPL satisfy the conditions for a Small-world networks. Another study (i.e., [16]) considering the European High Voltage Power Grid shows that the Small-world phenomenon is not shown by all the consid-

ered Grids, since especially the smaller (in terms of order and size) Grids fail to satisfy CC condition.

In summary, the Northern Netherlands Medium Voltage and Low Voltage samples show a very small value of average node degree. This is mainly independent from the size and the different purpose of the network being almost constant despite the different samples considered. In addition, the path length is quite high, given the order of the graphs, compared with other types of complex networks e.g., the World Wide Web. This relative high path length together with very small clustering properties suggests that the networks analysed do not strictly follow the definition of Small-world or, in terms of decentralized energy negotiation, it suggests that perhaps a structural change to decrease path length (especially the weighted one) might be necessary to empower delocalization. We provide an initial proposal in Section 7 on how to achieve this.

4.2 Node Degree Distribution

To have a general understanding of the overall characteristics of a network it is useful to compute certain statistical measures, one of which is the node degree probability distribution. More formally,

Definition 7 (Node degree distribution)**.** *Consider the degree k of a node in a graph as a random variable, the function*

$$N_k = \{v \in G : \ d(v) = k\}$$

is called node degree distribution*.*

The shape of the distribution is a salient characteristic of the network. For the Power Grid, the shape is typically either exponential or a power-law. More precisely an exponential node degree (k) distribution has a fast decay in the probability of having nodes with relative high node degree and follows a relation:

$$P(k) = \alpha e^{\beta k}$$

where α and β are parameters of the specific network considered. While a power-law distribution has a slower decay with higher probability of having nodes with high node degree:

$$P(k) = \alpha k^{-\gamma}$$

where α and γ are parameters of the specific network considered.

Power-law distributions are very common in many real life networks both created by natural processes (e.g., food-webs, protein interactions) and by artificial ones (e.g., airline travel routes, Internet routing, telephone call graphs), [25]. Having a power-law distribution for node degree means that few nodes have a very high degree and the majority of nodes have very small degree. The types of networks that follow this property are referred as Scale-free networks ([26, 27, 28]); typical examples of Scale-free networks are the World Wide Web, the Internet, metabolic networks, airline routes and many others. From the dynamic point of view, these networks are modelled by a preferential attachment model, that is, when new nodes and arcs are added to a graph, these are more likely to connect to nodes which have already a high degree, [29, 30]. In addition this network structure provides special reliability properties: high degree

of tolerance to random failures and, at the same time, very sensitive to targeted attacks towards hubs [28, 31, 18].

We compute the node degree distribution for every sample both for Low Voltage and Medium Voltage segments. For the most significant samples i.e., those belonging to the Medium Voltage and the big ones belonging to the Low Voltage part the node degree cumulative distribution seems to follow a power-law: $P_k \sim k^{-\gamma}$. A prompt method to investigate if the node degree follows a power-law is to plot the cumulative node degree distribution on a log-log scale [32]. If the distribution in a log-log plot follows a straight line the distribution can be considered a power-law, while if the decay is faster this might indicate an exponential distribution. It is also possible to apply data fitting techniques (e.g., non-linear least square method) to identify the γ parameter of a power-law.

The most significant samples for this kind of analysis are the biggest samples belonging to the Medium Voltage network and the most numerous ones from the Low Voltage (i.e., samples #5, #9 and #10 from Table 1). All these samples tend to follow a straight line in the log-log plot. Figures 2 and 3 show the distributions for Low Voltage samples, while Figures 4 and 5 show the probability distribution for the Medium Voltage ones.

We thus conclude that the Medium Voltage and Low Voltage tend to be Scale-free networks, although some exponential tail appear due to physical and economic constraints in the network. This means robustness in terms of redundancy of paths, but fragility to attacks on the hubs. The hubs tend to be the few nodes that most likely lead to the High Voltage segment in a certain geographical location.

4.3 Betweenness

Betweenness describes the importance of a node with respect to minimal paths in the graph. This is very important to identify critical components of the Power Grid [28, 31, 14]. For a given node, betweenness, sometimes also referred as *load,* is defined as the number of shortest paths that traverse that node.

Definition 8 (Betweenness)**.** *The* betweenness *of vertex $v \in V$ is the number of shortest paths between any two vertices in graph G that contain v, i.e.,*

$$b(v) = \sum_{v} \sigma_{st}(v)$$

where $\sigma_{st}(v)$ is the number of shortest paths from node s to node t traversing v.

The betweenness is an important measure because it allows to find if there are nodes that are critical for the whole infrastructure. In fact, the removal of nodes with the highest betweenness can lead to critical effects on the network connectivity [31].

For the most significant samples in the Low Voltage network (i.e., samples #5 and #10) betweenness probability distribution follows an exponential decay, that is, the nodes with very high values of betweenness are less likely to be present in the network, as shown in Figures 6 and 8. This aspect is not surprising since the Low Voltage network is quite hierarchical and the paths tend to follow the few ones admissible by the relative simple topology. In fact, the betweenness



Figure 2: Node Degree Cumulative Probability Distribution for Low Voltage sample #5. Circles represent sample data, while straight line represents a power-law with $\gamma = 2.402$.



Figure 3: Node Degree Cumulative Probability Distribution for Low Voltage sample #10. Circles represent sample data, while straight line represents a power-law with $\gamma = 1.494$.



Figure 4: Node Degree Cumulative Probability Distribution for Medium Voltage sample #2. Circles represent sample data, while straight line represents a power-law with $\gamma = 1.977$.



Figure 5: Node Degree Cumulative Probability Distribution for Medium Voltage sample #3. Circles represent sample data, while straight line represents a power-law with $\gamma = 2.282$.



Figure 6: Betweenness Cumulative Probability Distribution for Low Voltage sample #5 (logarithmic scale). Circles represent sample data, while continuous line represents an exponential decay $y = 0.7699e^{-2.227 \cdot 10^{-4}x}$.



Figure 7: Betweenness Cumulative Probability Distribution for Low Voltage sample #5 (semi-logarithmic scale). Circles represent sample data, while straight line represents an exponential decay $y = 0.7699e^{-2.227 \cdot 10^{-4}x}$.



Figure 8: Betweenness Cumulative Probability Distribution for Low Voltage sample #10 (logarithmic scale). Circles represent sample data, while continuous line represents an exponential decay $y = 0.6825e^{-6.798 \cdot 10^{-4}x}$.



Figure 9: Betweenness Cumulative Probability Distribution for Low Voltage sample #10 (semi-logarithmic scale). Circles represent sample data, while straight line represents an exponential decay $y = 0.6825e^{-6.798 \cdot 10^{-4}x}$.



Figure 10: Betweenness Cumulative Probability Distribution for Medium Voltage sample #2 (logarithmic scale). Circles represent sample data, while straight line represents a power-law with $\gamma = 1.178$.



Figure 11: Betweenness Cumulative Probability Distribution for Medium Voltage sample #3 (logarithmic scale). Circles represent sample data, while straight line represents a power-law with $\gamma = 1.075$.

probability distribution charts (Figures 6 and 8) do not fit a straight line in a logarithmic plot, exhibiting a fast decay. This impression is also reinforced by the charts in Figures 7 and 9, that is, the same betweenness probability distribution, but on a log-linear scale: the straight line in this kind of diagram is a sign of an exponential decay, [32]. In addition a fitting procedure, using the non-linear least square method gives very good results approximating the betweenness probability distribution samples with an exponential function. On the other hand, betweenness in Medium Voltage segment seems to follow a power-law decay, this is shown in the logarithmic chart in Figures 10 and 11. The samples from Medium Voltage network show a distribution of betweenness with a much fatter tail than the Low Voltage ones, that is there are nodes that are central in many paths. This is due to the more meshed structure the Medium Voltage network has, compared to the Low Voltage one. This result for Medium Voltage betweenness is closer to the results obtained for this same metric in High Voltage studies, [28, 14]. In summary, a few nodes are extremely critical to enable the electricity distribution to the whole network.

4.4 Node importance

To have a general understanding of the critical elements of the Grid, we resort to the matrix representation of the graph and study the eigenvalues and eigenvectors to find the most important and critical nodes of the network.

Definition 9 (Adjacency matrix)**.** *The adjacency matrix $A = A(G) = (a_{i,j})$ of a graph G is the $n \times n$ matrix given by*

$$a_{ij} = \begin{cases} 1 & \text{if } e_{i,j} = (v_i, v_j) \in E, \\ 0 & \text{otherwise.} \end{cases}$$

Centrality refers to the importance of the node in terms of degree, betweenness, closeness or eigenvectors [33, 34]. In this work, we use eigenvector centrality to stress the dependence of the centrality of one node with the centrality of the other nodes it is connected to. The components of the dominant eigenvector then represent the nodes of the graph. The highest the value, the highest the centrality of that node, the highest the importance of that node in the Grid.

The most critical nodes for the most interesting samples from Low Voltage are shown in Tables 3 and 4 while the results for samples from Medium Voltage are shown in Tables 5 and 6. The first column of each table represents the ranking position for the first ten node whose identifier is given in the second column. As mentioned above there are several measure to identify the most important nodes in a network. The core aspect of eigenvector centrality is that the importance of a node is dependent from the importance of their neighbouring nodes, and therefore to some extent from all nodes in a connected network. This is not the case for other measures of centrality (e.g., node degree centrality and betweenness centrality) whose values are not influenced by the properties of other nodes.

4.5 Fault tolerance

A related study is to evaluate the reliability of a network by analysing its connectivity when nodes are removed. There are basically two ways to perform this

Eigenvector Centrality Ranking #	Node ID
1	10
2	93
3	111
4	148
5	transformer 5
6	22
7	28
8	27
9	26
10	25

Table 3: Eigenvector centrality ranking for Low Voltage sample #5.

Eigenvector Centrality Ranking #	Node ID
1	3
2	44
3	108
4	39
5	109
6	110
7	102
8	107
9	2
10	61

Table 4: Eigenvector centrality ranking for Low Voltage sample #10.

Eigenvector Centrality Ranking #	Node ID
1	546
2	574
3	608
4	609
5	582
6	32
7	580
8	56
9	9
10	765

Table 5: Eigenvector centrality ranking for Medium Voltage sample #2.

analysis: choosing the nodes randomly or selecting the nodes to be removed following a certain property or metric significant for the network. Similar studies concerning the resilience of the High Voltage Power Grid exist, e.g., [16, 28]. We apply such technique to the Medium Voltage and Low Voltage ends of the Power Grid using three policies for node removal: random, highest degree and highest betweenness driven choices. The measure that is taken into account is the order of the largest connected component of the network (i.e., the number of nodes composing the biggest cluster in the network) computed as a fraction of the original order of the network, and its evolution while nodes of the network are removed, again the latter are considered as a fraction of the original order of the network.

The *random removal* simulates casual errors. As shown in [35], networks that follow a power-law whose characteristic parameter $\gamma < 3$ tend to have a high value for the transition threshold at which they disrupt. In the samples analysed it seems that this is true especially for the small samples that generally have a cluster that is 10% of the original when almost 90% of the nodes are removed, as shown in Figure 12. The situation is different for samples with higher order that show a cluster that is reduced to 10% of the original when about 40% of the nodes are removed, as shown in Figure 13. Even if the degree distributions found for samples following a power-law have a parameter $\gamma < 3$ the samples show a threshold effect that is more similar, according to [35], to networks whose characteristic $\gamma > 3$.

The situation is radically different when "targeted attacks" are considered. In particular two kind of attack policies are investigated: *node degree-based removal* and *betweenness-based removal*. The main difference compared to the random-based removal is the presence of very sharp falls that appear when certain nodes are targeted. The removal of selected nodes can cause a drop in the size of the maximal connected component even of 40%, as shown in Figure 14. Node degree-based removal is much more critical than the random removal: by just removing 10% of the most connected nodes one reduces the network to only 10% of its original size. The same applies for the biggest samples considered both in the Low Voltage and Medium Voltage network, as shown in Figures 17 and 18 for the Low Voltage and Figure 15 and 16 for the Medium voltage.

The removal of nodes based on the highest betweenness shows generally the

Eigenvector Centrality Ranking #	Node ID
1	351
2	263
3	324
4	6
5	12
6	350
7	299
8	11
9	80
10	355

Table 6: Eigenvector centrality ranking for Medium Voltage sample #3.



Figure 12: Resilience for random-based removal for Low Voltage sample #2. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.



Figure 13: Resilience for node random-based removal for Medium Voltage sample #2. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.



Figure 14: Resilience for node degree-based removal for Medium Voltage sample #10. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.



Figure 15: Resilience for node degree-based removal for Medium Voltage sample #2. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.



Figure 16: Resilience for node degree-based removal for Medium Voltage sample #3. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.



Figure 17: Resilience for node degree-based removal for Low Voltage sample #5. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.



Figure 18: Resilience for node degree-based removal for Low Voltage sample #10. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.

same behaviour, as degree-based removal, with network disruption that appear much faster than random-based network failures. Considering the general correlation between nodes with a certain degree and their betweenness it is not surprising that the two removal policies have very similar results and shape. The only remark that generally differentiates the betweenness-based removal is a little higher order of the maximal connected component compared to the one obtained with a degree-based removal when the same fraction of nodes is removed. In addition the decrease of the order of the maximal connected component tends to be slightly smoother than the degree-based one. Figures 19 and 20 show the comparison of the two removal policies for the samples that show some interesting deviations in the correlation of the degree and betweenness.

Another way to investigate the resilience is to determine which and how many edges have to be removed to break the graph into two disconnected components almost of the same order. This information is essential to have a general clue of the robustness of the Grid, that is how many transmission lines must be broken simultaneously to split the network in two components with almost the same amount of nodes, [19]. There are several methods and algorithms to solve this kind of problem that can be interpreted as a classic *max-flow/min-cut* problem, however an interesting method exploits the spectrum of the Laplacian matrix of a graph.

Definition 10 (Laplacian matrix)**.** *Let $D = (D_{ij})$ be a diagonal matrix with $D_{ii} = d(v_i)$ the degree of vertex v_i in graph G and A the adjacency matrix of G. The matrix $L = D - A$ is the Laplacian matrix of graph G.*

In particular this method exploits the second smallest eigenvalue of the Laplacian matrix of the corresponding graph and computes the corresponding eigenvector (for a complete explanation of eigenvalues of Laplacian matrix spectral properties we refer to [36, 37]). This resulting eigenvector has components, each one representing a node of the graph, that can be either positive or negative. Each node whose eigenvector component is positive belongs to one



Figure 19: Resilience for node degree-based and betweenness-based removal for Medium Voltage sample #10. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph. Red diamonds represent the betweenness-based removal, while blue circles represent the node node degree-based.



Figure 20: Resilience for node degree-based and betweenness-based removal for Medium Voltage sample #13. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph. Red diamonds represent the betweenness-based removal, while blue circles represent the node node degree-based.

sub-graph, while the ones with negative components belong to the other sub-graph. The edges that connect nodes belonging to the different sub-graphs are the critical edges that if removed lead to two different sub-graphs. The more edges connect the two sub-graphs, the more robust is the Grid. Once the two sub-graphs are identified it is possible to iterate the method on each sub-graph and find again the most critical edges.

The number of critical edges that, if removed at the same time, disrupt the network evenly in two or more sub-networks, are shown in Table 7 and Table 8 for Low Voltage and Medium Voltage respectively. The first column represent the sample identifier, while the second column represent the number of edges to be removed simultaneously to split evenly the network. Generally Medium Voltage networks are more robust to edge failures than Low Voltage with the number of edges to be removed that is double. Medium Voltage sample #2 is the most reliable to line disruption attack and indeed this is an indication of the high mashed structure the biggest sample analysed owns.

Sample #	Number of Critical Edges
1	2
2	2
3	2
4	1
5	2
6	2
7	1
8	1
9	2
10	3
11	1

Table 7: Number of critical edges according to Laplacian eigenvalue method for Low Voltage samples.

Sample #	Number of Critical Edges
1	2
2	27
3	4
4	5
5	3
6	4
7	4
8	1
9	6
10	4
11	4
12	1
13	6

Table 8: Number of critical edges according to Laplacian eigenvalue method for Medium Voltage samples.

In summary, the results for the Low Voltage and Medium Voltage show

disruption behaviours. These networks are quite immune to random failures to which the networks present a constant degrading disruption, while they deeply suffer from certain characteristic nodes to be removed.

5 Weighted Power Grid study

The purely topological study of the Power Grid just presented already gives important information about the connectivity and robustness of the Medium and Low Voltage Grids, though it does not consider the different physical properties of the cables. These can vary greatly for different sections of the Grid and provide essential indications to establish the behaviour of a link. Next we perform an analysis of the same samples of the Grid also considering the resistance as the weight of the graph model of Definition 2.

ID	Weighted Characteristic Path Length	Edge Average Weight	Normalized Weighted Characteristic Path Length
1	2.000	0.698	2.865
2	1.429	0.595	2.402
3	3.066	0.739	4.149
4	3.087	0.699	4.414
5	12.136	0.741	16.378
6	3.889	1.648	2.360
7	4.162	0.348	11.960
8	5.112	0.876	5.836
9	7.872	0.583	13.503
10	6.407	0.785	8.162
11	2.967	0.592	5.012

Table 9: Weighted analysis of the Low Voltage samples from the northern Netherlands Power Grid.

Take the samples analyzed in Tables 1 and 2, but now consider the weighted graph definition. The notion of a characteristic path length can be extended to take the weights into account yielding the values shown in Tables 9 and 10. In each table, the second column contains the characteristic path length resulting in the weighted graph (WCPL), formally:

Definition 11 (Weighted characteristic path length (WCPL))**.** *The* weighted characteristic path length *for graph G, L_{wcpl} is the median for all $(v_i, v_j) \in V$ of the following distance*

$$d_w(v_i, v_j) = \sum_{e_{s,t}} e_{w_{s,t}}$$

such that $e_{w_{s,t}}$ is an edge in the minimal weighted path between v_i and v_j.

The third column provides the average value of the weights of all edges; while the fourth column shows a normalized value for the weighted characteristic path length (NWCPL) obtained by dividing the WCPL by the average weight of the edge belonging to the same data sample. This normalization is performed to have a measure to compare the unweighted and the weighted samples whose results are shown in Section 6.

ID	Weighted Characteristic Path Length	Edge Average Weight	Normalized Weighted Characteristic Path Length
1	185.916	12.779	14.549
2	108.011	11.851	9.987
3	153.402	8.608	17.821
4	163.067	9.217	17.692
5	127.258	7.122	17.868
6	134.661	13.106	10.275
7	187.084	16.382	11.420
8	148.058	7.193	20.584
9	99.385	7.421	13.392
10	126.845	6.850	18.518
11	92.060	8.764	10.504
12	38.084	6.915	5.507
13	232.475	13.810	16.834

Table 10: Weighted analysis of the Medium Voltage samples from the northern Netherlands Power Grid.

Due to the relative short length of the Low Voltage networks cables, the WCPLs for this segment of the network are small, as well as the average weight of each edge (almost all of them are below the unit). The situation is different for the Medium Voltage networks which are higher since the cables and paths span across wider geographical areas. The discrepancy can be explained by the different purpose for which these networks are designed: a bridge network from High Voltage transmission lines and end-user distribution (Medium Voltage network) and the final end delivery (Low Voltage network). In fact, both the WCPL and the edge average weight for Medium Voltage samples are approximately two order of magnitude greater than the Low Voltage ones. This is indeed due to an extension of Medium Voltage cables that range from hundred meters to kilometres, while Low Voltage extend usually around tens of metres.

5.1 Weighted Node Degree Distribution

Though no value is associated to a node, the weights of the incident edges also influence the node properties. One way of seeing this, is by defining a weighted node degree.

Definition 12 (Weighted degree)**.** *Let $x \in V$ be a vertex in a weighted graph G, the* weighted degree *of x, $d_w(x)$ is:*

$$d_w(x) = \sum_{y \in \Gamma(x)} w_{x,y}$$

where $w_{x,y}$ is the weight of the edge joining vertices x and y and $\Gamma(x)$ is the neighbourhood of x.

The weighted distribution is straightforwardly obtained by using the weighted degree in Definition 7.

For the most significant sample of the Low Voltage, as shown in Figures 21 and 22, the shape of the distribution is close to an exponential one with a quite



Figure 21: Weighted Node Degree Cumulative Probability Distribution for Low Voltage sample #5 (logarithmic scale). Circles represent sample data, while continuous line represents a sum of exponential decays $y = 0.8975e^{-0.9289x} + 0.0904e^{-0.1379x}$.

fast decay. The situation looks different in Medium Voltage samples. The very first part of the distribution is well fitted by an exponential shape, while the central part of the distribution, and especially the tail, fit best a power-law like shape as visible in Figures 23 and 24. An explanation of such behaviour between the the most numerous samples of the two ends of the Grid is due to the order and size of the Medium Voltage samples which are from two to four times bigger than the Low Voltage samples, thus having a higher likelihood of far different values in weighted node degree.

5.2 Betweenness

Considering the weighted definition of path it is possible to compute betweenness in the weighted scenario and again betweenness of a node can be seen as a random variable thus obtaining the corresponding probability distribution. The shape of the distribution does not change much compared to the same unweighted samples for the Low Voltage network, as shown for samples #5 and #10 in Figures 25 and 26: the distribution is best approximated by an exponential decay or by a sum of exponential contributions. For Medium Voltage samples, the changes between unweighted and weighted paths influence the betweenness probability distribution whose shape in these conditions seems to be better approximated by an exponential or sum of exponential components as shown in Figure 27. This change in the distribution of the number of shortest paths that traverse a node between the weighted and the unweighted graph is clearly an indication that some property change between the two analysis and it is worth to remember that the weighted path analysis better approximate the actual routes current flows follow.



Figure 22: Weighted Node Degree Cumulative Probability Distribution for Low Voltage sample #10 (logarithmic scale). Circles represent sample data, while continuous line represents a sum of exponential decays $y = 0.1538e^{-21.47x} + 0.8378e^{-0.4909x}$.



Figure 23: Weighted Node Degree Cumulative Probability Distribution for Medium Voltage sample #2 (logarithmic scale). Circles represent sample data, while straight line represents a power-law with $\gamma = 1.354$.



Figure 24: Weighted Node Degree Cumulative Probability Distribution for Medium Voltage sample #3 (logarithmic scale). Circles represent sample data, while straight line represents a power-law with $\gamma = 1.374$.



Figure 25: Betweenness Cumulative Probability Distribution for Low Voltage sample #5 considering the weighted graph (logarithmic scale). Circles represent sample data, while continuous line represents a sum of exponential decays $y = -0.1051e^{3.381 \cdot 10^{-6}x} + 0.8084e^{-1.317 \cdot 10^{-4}x}$.



Figure 26: Betweenness Cumulative Probability Distribution for Low Voltage sample #10 considering the weighted graph (logarithmic scale). Circles represent sample data, while continuous line represents an exponential decay $y = 0.6456e^{-6.139 \cdot 10^{-4} x}$.



Figure 27: Betweenness Cumulative Probability Distribution for Medium Voltage sample #3 considering the weighted graph (logarithmic scale). Circles represent sample data, while continuous line represents a sum of exponential decays $y = 0.6582e^{-2.648 \cdot 10^{-4} x} + 0.3939e^{-5.060 \cdot 10^{-5} x}$.

5.3 Node Importance

The criticality or importance of nodes in the network is best studied using weights. In fact, an edge with high capacity (i.e., weight) makes a node very important, conversely many edges with little capacity (i.e., weight) make a node almost irrelevant. The approach considered is similar to the one leading to the eigenvector centrality computation performed in Section 4.4. However, to compute this metric, a weighted form of the adjacency matrix is necessary (cf. Newman [38]).

Definition 13 (Weighted adjacency matrix)**.** *The weighted adjacency matrix* $A_w = A_w(G) = (a_{i,j})$ *of a graph* G *is the* $n \times n$ *matrix given by*

$$a_{ij} = \begin{cases} w_{ij} & \text{if } v_i v_j \in E \text{ and has weight } w_{ij}, \\ 0 & \text{otherwise.} \end{cases}$$

Computing the eigenvector corresponding to the principal eigenvalue, one obtains a ranking among the various nodes of the network. The results for eigenvector centrality for two Medium Voltage samples are shown in Tables 11 and 12 while for two Medium Voltage samples are shown in Tables 13 and 14. The first column of each table represents the ranking position for the first ten node whose identifier is given in the second column. It is interesting to note that with this ranking the first ten most important nodes of the graph, and to a certain extent critical substations for the Power Grid, are in general different than those of the unweighted analysis. This aspect reinforces a consistent difference in node properties between the two type of analysis performed.

Eigenvector Centrality Ranking #	Node ID
1	192
2	191
3	6
4	24
5	137
6	130
7	135
8	129
9	178
10	transformer 3

Table 11: Eigenvector centrality ranking for Low Voltage sample #5 considering the corresponding weighted graph.

5.4 Fault tolerance

Fault tolerance can be evaluated based on the removal of nodes following strategies similar to the unweighted case. Since the random removal yields exactly the same result for the weighted and unweigted case, here we focus on the node degree-based removal policy which considers the weighted node degree definition. The disruption behaviour of the network samples is very similar to the unweighted situation: the network suffers deeply these targeted attacks; a very

Eigenvector Centrality Ranking #	Node ID
1	3
2	44
3	108
4	5
5	107
6	55
7	110
8	109
9	102
10	39

Table 12: Eigenvector centrality ranking for Low Voltage sample #10 considering the corresponding weighted graph.

Eigenvector Centrality Ranking #	Node ID
1	577
2	580
3	575
4	822
5	702
6	706
7	546
8	578
9	170
10	90

Table 13: Eigenvector centrality ranking for Medium Voltage sample #2 considering the corresponding weighted graph.

Eigenvector Centrality Ranking #	Node ID
1	324
2	351
3	263
4	350
5	299
6	410
7	393
8	48
9	124
10	80

Table 14: Eigenvector centrality ranking for Medium Voltage sample #3 considering the corresponding weighted graph.



Figure 28: Resilience for weighted node degree-based removal for Low Voltage sample #5. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.

small percentage of removed nodes causes an important loss in the size of the biggest component left in the network. The comparison between Figures 28 and 17 for the Low Voltage samples, and Figures 29 and 15 for the Medium Voltage samples provides a general correlation between high degree nodes in the unweighted graph and high degree nodes in the weighted one. If one takes a closer look at the disruption charts for the same samples some small differences can anyway be noticed. The nodes with the highest weighted degree cause a bigger damage to the network when removed in the very first iteration than nodes with higher degree in unweighted networks, this behaviour is shown in Figures 30 and 31. The situation then changes in the later stages of the removal process when a bigger disruption is caused by nodes with higher node degree in *traditional sense*.

6 Unweighted vs. Weighted comparison study

The weighted study of the Power Grid presented in the previous section has already highlighted the more precise information available with such study. Next we consider more in detail the comparison between the unweighted and weighted study for the most indicative measures.

Considering a minimal path, one may wonder if introducing weights changes the number of traversed nodes by such minimal paths on average. Even if the WCPL and the NWCPL values are close, there might be differences in the number of nodes and (therefore edges) traversed when following a minimal path. This is particularly interesting from the practical point of view, as it indicates the number of transformers and distribution substations traversed in the Power Grid. These points are critical in terms of additional losses that are associated with substations and transformers, and in turn in the number of potential points of failure that a path traverses. Figures 32 and 33 show the results for the Low Voltage and Medium Voltage, respectively. Each bar



Figure 29: Resilience for weighted node degree-based removal for Medium Voltage sample #2. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph.



Figure 30: Resilience for node degree-based removal for Medium Voltage sample #3. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph. Red diamonds represent the weighted node degree-based removal, while blue circles represent *traditional* node degree-based removal.



Figure 31: Resilience for node degree-based removal for Low Voltage sample #10. The horizontal axis represents the fraction f of the nodes removed from the original sample; the vertical axis represents the size of the largest connected component S relative to the initial size of the graph. Red diamonds represent the weighted node degree-based removal, while blue circles represent *traditional* node degree-based removal.



Figure 32: Percentage increase in number of node traversed between weighted and un-weighted Low Voltage samples.



Figure 33: Percentage increase in number of node traversed between weighted and un-weighted Medium Voltage samples.

represents the average percentage increase in the number of nodes traversed along the shortest path between any two nodes for the unweighted and the weighted situation. It is interesting to note that for several samples of the Low Voltage there is no difference in the number of traversed nodes, thus reinforcing the idea of a highly hierarchical tree-like structure whose paths are fixed by the built-in topology of the Grid independently of the associated edge weights. The situation though is quite different for the Medium Voltage. In fact there is an increment of traversed nodes between the weighted and unweighted models (especially for the meaningful samples) on average of about 50%. This is a clear indication of a meshed network for which there are less imposed paths and in which the weights have an important role. It is important to notice that for the biggest sample (almost 900 nodes) the number of visited nodes when following a path between any two nodes increases by more than 80% comparing the unweighted and the weighted situation.

Considering the node degree distribution it seems that the weighted analysis tends to reduce the contribution of the tail components of the distribution, thus being more compact especially for Low Voltage samples. This is due to the small variance of the weighted node degree that especially these low-end samples of the Grid show. Samples that in the unweighted analysis show a power-law distribution, when considered weighted tend to assume an exponential form or a sum of exponential contributions. The biggest samples analysed in the Medium Voltage (samples #2 and #3) tend to even have a faster decay than the unweighted situation. The same consideration applies to the betweenness probability distribution which for the Low Voltage samples still shows a best approximation by an exponential decay. For the samples belonging to the Medium Voltage the same tendency appears: a more compact distribution of

the number of paths traversing nodes.

Considering a representation of the relationships between nodes and their weights, the ranking of importance obtained with the eigenvector centrality computation between nodes changes substantially. This is understandable since the weight deeply influences the properties, and therefore importance, of a node. This dissimilarity in node characteristics is also shown by the different behavior the removal of the highest degree nodes brings to the network connectivity. Although the general behavior functioning similar, the first nodes removed with the highest weighted degree tend to have a more damaging impact than the corresponding policy removal in an unweighted graph, this behavior then tends to reverse while removing more and more nodes: the most damaging results in term of network connectivity is then caused by nodes with highest degree in the unweighted network. The comparison between weighted and unweighted node degree-based removal is shown in Figure 31 for a Low Voltage sample and in Figure 30 for a Medium Voltage sample.

7 Topological influence on Energy Exchanges

Traditionally, energy has been 'pushed' hierarchically from the large scale production facilities to the end users. Famous is the quote of Samuel Insull (XIX century):

> *"every home, every factory and every transportation line will obtain its energy from one common source, for the simple reason that that will be the cheapest way to produce and distribute it."*

Clearly, things are rapidly changing on today's Power Grid and new models are emerging where delocalized production is the norm, rather than the exception. The trend will call for an infrastructure that supports energy trading among any actor connected to the Power Grid.

The Complex Network Analysis that we provided so far gives a statistical aggregated view of the current infrastructure for the Low and Medium Voltage Grids. The natural next question that arises concerns the usability of such infrastructure for the delocalized energy exchange. To answer it, we propose to tie statistical properties of the Power Grid with a trading cost. The cost represents a balance frontier below which the actors are motivated to trade and above which they are not. It is important to remark that we do not claim of having identified "the" cost function, but rather we propose that Complex Network Analysis measures are deeply connected to the success of a decentralized energy market.

7.1 Relating topology to price

In general, establishing energy pricing is not a simple task since several aspects influence the overall price at which electricity is sold. There are aspects connected to the supply side such as fuel prices, policy regulations, load losses and bidding strategies; on the other hand, there are elements connected to the demand side such as human behaviors, natural phenomena that influence habits and thus consumption. Recent proposals and methods for price allocation include *nodal pricing* [39], which is particularly indicated for distributed generation solutions because of the price benefits it brings to the customer [40]. It is

also important to notice that the savings deriving from distribution losses can be extremely important [41, 42, 43]. A set of factors is most definitely tied to infrastructural properties of the distribution network, as illustrated for instance in the economic studies of Harris and Munasinghe [44, 45], most notably:

- losses both in line and at transformer stations,
- security and capacity factors,
- line redundancy, and
- power transfer limits.

The listed technical parameters are naturally associated with a topological parameter, namely:

- Line losses are related to and thus expressed as a function of the weighted characteristic path length $L_{line_N} = f(WCPL_N)$
- Substation losses are expressed as a function of the (average) number of nodes visited while travelling from source node to destination node along the weighted shortest path $L_{substation_{ij}} = f(|WSP_{ij}|)$. The significant dimension is $L_{substation_N} = f(\overline{|WSP_N|})$ where $\overline{|WSP_N|}$ is the average number of nodes traversed in a shortest path in the network N.
- Robustness from a topological perspective is expressed as the fraction of the maximal connected component compared to its original size once a certain fraction of nodes is removed. $Rob_N = f(N, p)$ where N is the network under evaluation and p is the removal policy adopted.
- Line redundancy is simply mapped to a topological metric that counts the number of paths (without cycles) that are available between any two nodes and the cost associated to this redundancy $Red_{ij} = f(|P_{ij}|, w_{ij})$ where P_{ij} is the set of paths between nodes i and j and w_{ij} is the weight of the worst case redundant path. A global metric for network N is $Red_N = f(\overline{|P_{ij}|}, \overline{w_{ij}}), \forall i, j \in N$
- Network capacity may be considered as a function of the weighted characteristic path length where the weight is the maximal supported operating current of the cable $Cap_N = f(WCPL_N)$

These topological ingredients provide two sorts of measures, the first one α gives an average of the dissipation in the transmission between two nodes

$$\alpha = f(L_{line_N}, L_{substation_N}); \tag{1}$$

the second one β is a measure of reliability/redundancy in the paths among any two nodes

$$\beta = f(Rob_N, Red_N, Cap_N). \tag{2}$$

We argue that these two factors influence the inclination of prosumers (energy consumers/producers) to trade energy on the Power Grid. In fact a high value of the α parameter represents a high level of losses experienced for transporting



Figure 34: Transport cost of energy based on the topological properties for Low Voltage samples.



Figure 35: Transport cost of energy based on the topological properties for Medium Voltage samples.

energy in the network, either in distribution lines or substations. Additionally, the reliability and ability to bring sufficient energy to the end users plays an important role. In fact, if proper levels of robustness of the network or resilience to failures are not the norm, the prosumer inclination to sell energy as well as the end user to buy it will be limited. Furthermore, if the availability of redundant paths for electricity routing in case of partial disruption of the network are insufficient leads to a high value of β, and in turn a disincentive for trading. To better understand the constituents of α and β, we consider next a possible instantiation of these parameters using the data of the Dutch Power Grid.

7.2 An example

To give an impression of how the parameters can be used to assess the success of the energy market, we provide an example next. We stress that this is simply an example, and it does not have the ambition to provide the successful parameter for the delocalization of the energy distribution market.

- Losses on the transmission/distribution line can be expressed by the quotient of the weighted characteristic path length and the average weight of a line (a weighted edge in the graph):

$$L_{line_N} = \frac{WCPL_N}{\overline{w}}$$

- Losses at substation level are expressed as the number of nodes (on average) that are traversed when computing the weighted shortest path between all the nodes in the network:

$$L_{substation_N} = \overline{Nodes_{WCPL_N}}$$

- Robustness is evaluated with random removal strategy and the weighted node degree-based removal by computing the average of the order of maximal connected component between the two situations when the 20% of the nodes of the original graph are removed. It can be written as:

$$Rob_N = \frac{|MCC_{Random20\%}|+|MCC_{NodeDegree20\%}|}{2}$$

- Redundancy is evaluated by covering a random sample of the nodes in the network (40% of the nodes whose half represents source nodes and the other half represents destination nodes) and computing for each source and destination pair the first ten shortest paths of increasing length. If there are less than ten paths available, the worst case path between the two nodes is considered. To have a measure of how these resilient paths have an increment in transportation cost, a normalization with the weighted characteristic path length is performed. We formalized it as:

$$Red_N = \frac{\sum_{i \in Sources, j \in Sinks} SP_{w_{ij}}}{WCPL}$$

- Network capacity is considered as the value of the weighted characteristic path length, whose weights are the maximal operating current supported, normalized by the average weight of the edges in the network (average current supported by a line). That is:

$$Cap_N = \frac{WCPL_{currentN}}{w_{current}}$$

With these instantiations, equations (1) and (2) become:

$$\alpha = f(L_{line_N}, L_{substation_N}) = L_{line_N} + L_{substation_N} \tag{3}$$

$$\beta = f(Red_N, Rob_N, Cap_N) = \frac{Red_N}{Rob_N \cdot ln(Cap_N)} \tag{4}$$

The functions to compute α and β are only few of many available possible ones. The choice made here is to have a simple mechanism to assess the potential exchange costs of different networks. Equation (3) is a basic sum over the losses that are experienced both at line and at substation level. Equation (4) takes into account the aspects of reliability and tolerance of the network: the higher the β the more prone to failures and less reliable the network is. The cost of increasing the number of paths to provide more redundancy is the dividend in the fraction, while elements improving reliability act as divisor.

With these quantities, one can form an impression of what the influence of the cost of transportation is for the decentralized energy exchange. If the cost is too high because of an infrastructure with high chances of failure (high β) and high resistance (high α), then the decentralized market will not be incentivized. On the other hand, for low α, β, it will be economically attractive to have a decentralized energy market. In Figures 34 and 35, we show a combination of α, β obtained with the functions described above and with an hypothesis of a quadratic increase of energy price with the increment in α and β. We report the position of the analysed samples as white circles in Figures 34 and 35 respectively for Low Voltage and Medium Voltage samples. By performing an economic study, which we stress is beyond the scope of the present treatment, one then can identify what the threshold is for the feasibility of a decentralized market (grey area in Figure 36) and then conclude what topological modifications are necessary to the Medium Voltage and Low Voltage infrastructure in order to allow the energy exchange.

8 Related Work

Complex Network Analysis studies are becoming more and more popular given the amount of natural and human based complex systems. The Power Grid is clearly amenable to such study and a number of these have been performed on the High Voltage Grid around the globe. These have been an inspiration for the present work which though is novel in its analysis of the Medium Voltage and Low Voltage, in its use of weights, and its motivation stemming from energy negotiation by micro/medium prosumers. Next we survey the most notable related work.

Albert *et al.* [46] study the reliability aspects of the United States Power Grid. In extreme summary this work is particularly relevant for the big sample it analyses representing the whole North American High Voltage Power Grid and focusing in illustrating the cascading effects evaluating a connectivity loss property the authors define. The effects affecting the Power Grid based on this metric show important differences between the various policies of node removal (random, node degree or betweenness based). Betweenness computation is remarkable as it is used to identify the important nodes in the network, however



Figure 36: Transport cost of energy based on the topological properties for Medium Voltage with supposed economic convenience threshold (grey thick line).

the article does not take into account any sort of weight to be associated to the power lines.

Crucitti *et al.* [14] analyse the Italian High Voltage Power Grid from a topological perspective. This work is particularly relevant for the concept of efficiency that is used to understand the performance of the network. This metric is evaluated as a function of the tolerance of load both for edges and nodes. It is interesting that some sort of weights are used for this analysis: a capacity measure is associated with nodes while weight is associated with edges based on residual capacity of nodes. In this article too, some strategies of failure simulation are taken into account (random and betweenness-based removal). However, the size of the sample analysed is small compared to other works and the type of weight attributed to edges is not related to any physical quantity (e.g., lines resistance), but is only related to topological betweenness.

A different model is presented by Chassin *et al.* [12] where the analysis focuses on the North American Power Grid. The authors start with the hypothesis that the Grid can be modelled as a Scale-free network. This work is extremely relevant for the large size of the sample analysed (more than 300000 nodes) and the use of reliability measures that are typical of power engineering (e.g., loss of load probability) to quantify the failure characteristics of the network from a topological point of view. The similarity of the results obtained by considering reliability with authors' topological measures and other non topological studies for electrical Grids is interesting. However, a study of betweenness is unfortunately missing. Given the size of the sample (although it is not explicitly stated if Medium Voltage components are considered or not) it would have useful to compute the betweenness of the nodes in order to understand if and how the betweenness behaves in this sort of big sample.

Holmgren [15] analyses the Nordic Power Grid involving the High Voltage Grids of Sweden, Finland, Norway, and a great part of Denmark comparing

Work	Sample Order	Sample Type	Network Type	Node Degree Distribution Statistics	Betweenness Distribution Statistics	Weighted/Unweighted Analysis	Resilience Analysis	Small-world Investigation
Albert *et al.* in [46]	∼14000	Real	HV	✓	✓	Unweighted	✓	
Crucitti *et al.* in [14]	∼300	Real	HV	✓	✓	Weighted not based on physical properties	✓	
Chassin *et al.* in [12]	∼314000	Real	HV	✓		Unweighted	✓	
Holmgren *et al.* in [15]	∼4800	Real	HV	✓		Unweighted	✓	✓
Casals *et al.* in [17]	∼2800	Real	HV	✓		Unweighted		
Casals *et al.* in[16]	∼3000	Real	HV	✓		Unweighted	✓	✓
Sole *et al.* in[47]	∼3000	Real	HV	✓		Unweighted	✓	
Crucitti *et al.* in[20]	∼130	Real	HV			Unweighted	✓	
Rosato *et al.* in[19]	∼130	Real	HV	✓		Unweighted	✓	
Watts *et al.* in[24]	∼4900	Real	HV			Unweighted		✓
Wang *et al.* in[8]	∼8500	Synthetic and real	HV	✓		Unweighted and impedence analysis		✓
Present Study	**∼4850**	**Real**	**MV/LV**	✓	✓	**Both**	✓	✓

Table 15: Comparison table between literature studies using Complex Network Analysis applied to Power Grid networks.

these with the U.S. Power Grid. A resilience analysis is performed and with the inclusion in this work of some fictitious scenarios of failure of the Grid and the possible adoptable solutions together with their resulting benefits. A computation of the betweenness property of the graph might have been useful to understand the differences between the different samples; also a weighted graph study might have pointed out even more interesting aspects between the various networks, but these are missing.

Casals *et al.* [17] analyse the whole High Voltage European Power Grid and try to extract non-topological reliability measures investigating the topological properties of the network. The Power Grid analysed is the High Voltage end composed of almost 2800 nodes that span across the European continent. The assumption is that node degree distribution follows an exponential decay for every single network composing the European network, each one having a characteristic parameter that is related to the *robustness* of the specific Grid. Although this study is based on relevant samples, but half of the considered Grids are small both in size and order (below 100 nodes). The most interesting aspect is the use of new indicators to assess network reliability, but, as the same authors explicitly state, these metrics need more test and a deeper study. As remarked for other works, there is no mention about using weights to characterize the edges in the networks.

Casals *et al.* [16] consider the High Voltage Grids of many European countries analyzing them together and as separate entities. This work has an overall relevant sample although no information are given for each single Grid which might

have smaller significance when analysed alone. The most interesting aspects are the evaluation of Small-world properties for the networks composing the European Grid and the resilience test with both random and node degree-based removal strategies. There is no mention about using weights to characterize the edges in the network and no betweenness computation to find out critical nodes in term of paths covered.

Sole *et al.* [47] go further in exploring the same Power Grid data analysed in [16], in particular they focus on targeted attacks. The model is based on the assumption, also verified by empirical data, that there is no correlation between nodes having a certain degree to be connected to each other. This work has an overall relevant sample and it focuses on simulating different failure events (random or targeted), establishing an interesting correlation between topological and non-topological reliability studies. The major point of improvement is related to the small size of half of the samples used (below 100 in order) and the possibility of introducing weights for edges related to some of the physical properties. In addition, an evaluation of the betweenness is missing in order to understand if other nodes appear to be critical and so to be targeted using this different removal metric.

Crucitti *et al.* [20] analyse the High Voltage Power Grid of Italy, France and Spain to detect the most critical lines and propose solutions to address their vulnerabilities. This work has some very valuable aspects such as the comparison of the Grids of three different countries (i.e., Italy, France and Spain), the identification of the most vulnerable edges, the damage provoked by an attack and possible improvements based on the efficiency metric. The sample used is considerably small; in addition there is no use of weights to characterize the edges. Thus it is not possible to discover which is the weight of the most critical edges identified and if there is a correlation with the unweighted analysis.

Rosato *et al.* [19] analyse the same network samples studied in [20] to investigate the main topological properties of these Grids (i.e., Italian, French and Spanish High Voltage Grids). The contributions of this work include the comparison of the Grid of three different countries, the identification of the most vulnerable edges, and the damage of an attack and achievable improvements based on adding edges. It also studies the node degree distribution and the shortest path length distribution for these samples. It is interesting to note how the authors clearly show the correlation between country geography and topological measures. The sample used is notably small; in addition there is no use of weights to characterize the edges.

Watts [24] dedicates a subsection of his book to exploring the properties of the Western States Power Grid. The study gives motivations to the Small-world modeling. The analysis focuses on specific metrics such as network contraction parameters and the comparison between different models (i.e., relational and dimensional models). Therefore being Small-world the focus of the analysis, other typical Complex Network Analysis measuring are not performed (e.g., node degree distribution, betweenness distribution).

Wang *et al.* [8] study the Power Grid to understand the kind of communication system needed to support the decentralized control required by the Smart Grid. The analysis is based both on real Power Grid samples and synthetic reference models belonging to the IEEE literature. This work has some very valuable aspects such as the investigation of a significant sample, the individuation of a new model for the node degree probability distribution, and

the investigation of the physical impedance distribution of the Grid samples. All these factors bring to the development of a new model to characterize the Power Grid. An aspect that might have been analytically evaluated is the path length in the various samples analysed and the betweenness computation to characterize even those distribution analytically. The use of electrical properties is extremely interesting, however the analysis performed is dissociated to the physical graph properties therefore not considering a weighted graph structure.

There are also some brief studies related to the Power Grid that appear as examples in more general discussions about Complex Networks. In particular, Amaral *et al.* in [32] show a study of the Southern California Power Grid and the model following an exponential decay for node degree distribution. Watts and Strogatz in [21] show the Small-world phenomenon applied to the Western States Power Grid while Newman, within a more general work [48], shows the exponential node degree distribution for the same Grid, while Barabasi *et al.* [49] model the Power Grid as a Scale-free network characterized by a power-law node degree distribution.

As shown in Table 15 the analysis performed in the present study has a sample significant in size (considering the singles samples altogether) higher than most other studies of the High Voltage network. The new aspects that make the present analysis unique are the focus on the Medium Voltage and Low Voltage network that no other study takes into account, and also the usage of weighted graph that other studies miss. In addition, the analysis is complete investigating betweenness and resilience analysis through the computation of various failure policies. Nonetheless the analysis examines the Small-world property for the Medium Voltage and Low Voltage network showing how the samples under exam do not belong to this class of networks.

9 Conclusions

When facing a global complex system such as the Power Grid, it is necessary to combine precise tools to consider the local phenomena with global statistical tools that provide an overall view. In the present study, we look with a weighted model at the Medium and Low Voltage Grids with the aim of understanding its potentials as infrastructure for delocalized energy distribution. The study takes the North Netherlands data as basis for its analysis and proposes and adapts a number of statistical topological measures for the specific goal.

A number of novelties are a trademark of the current proposal: the study of the lower layers of the Power Grid, the study of energy distribution rather than simply resilience, the use of a weighted topological model and, most notably, the proposal of tying the topological properties to values denoting the attractiveness for the prosumers to trade energy. But let us be more specific in summarizing the results of the present treatment.

An interesting aspect is the difference experienced in the shortest path between the weighted and unweighted graph. The difference is most notable in the number of nodes that need to be traversed. This is interesting since the weighted paths considering resistance are closer to the ones really travelled by the energy flow, therefore traversing much more nodes than the ideal situation can lead to additional losses in substations and transformers together with a larger number of potential point of failure.

Considering graph statistical properties, the node degree distributions tend to follow a power-law (at least for the most significant samples), that is there are few nodes that have many connections, while the majority has a very limited number. As the literature shows there is quite a common consensus about the type of node degree distribution High Voltage Power Grids have, i.e., exponential, while a study that takes into account many more nodes obtains a power-law distribution [12]. The explanation of the Medium and Low Voltage Grids may reside in the relatively small number of stations and transformers that receive their input from the High Voltage network and have to distribute this input to many more substation at lower voltages.

The betweenness plots have a specific characteristic for the Low Voltage samples: unlike what presented in the literature reporting a power-law characterizing the High Voltage, the Low Voltage follows an exponential decay. The topology itself of the Low Voltage network, in which the paths are much more forced due to the greater hierarchy of the Low Voltage network, implies a betweenness distribution with a more compressed tail than a fat-tailed power-law. While a more meshed network as the Medium Voltage has more nodes that take part in different number of paths.

Another remarkable aspect is the relatively higher tolerance that is shown by the Medium Voltage network when edges are removed compared to the Low Voltage network. This is due to the more meshed structure of the Medium Voltage which is therefore less prone to failures than the Low Voltage. In fact, the average number of links that need to be eliminated at the same time to cut the network in two or more components are more than the ones for Low Voltage.

From these findings, we move towards our claim, that is, the influence of these global topological factors on the actual possible use of the Power Grid as an infrastructure for delocalized energy exchange. We make an initial proposal of how the Complex Network Analysis topological metrics can be clustered in two parameters α and β that need to be optimized in order to facilitate energy negotiation among prosumers. To optimize them, one may have to change the topological properties of the Grid. It might turn out that to reduce the WCPL needs to lay more cables between rural and urbanized areas, or to put more interconnections between neighboring urbanized areas.

Clearly there is much more to be investigated in the direction of Complex Network Analysis for the Power Grid. The models need to be enriched with ever more Power Grid specific characteristics. The dynamics of the growth of the Power Grid may also provide new insights. Simulations of possible future scenarios will also help to identify the right infrastructure of the future (Smart) Grid, not to mention the importance of coupling such technical studies with their economic counterparts.

Acknowledgment

The authors thank Hanzehogeschool Groningen in the person of Peter Kamphuis, Enexis B.V. in the person of Hemmo Hulzebos and Phase-to-Phase B.V. in the person of Berto Jansen for the Grid data and useful information. Pagani is supported by University of Groningen with the Ubbo Emmius Fellowship 2009. The work is supported by the Dutch National Research Council under the NWO Smart Energy Systems programme, contract no. 600.647.000.004.

References

[1] C. W. Anderson, J. R. Santos, and Y. Y. Haimes, "A Risk-based Input-Output Methodology for Measuring the Effects of the August 2003 Northeast Blackout," *Economic Systems Research*, vol. 19, no. 2, pp. 183–204, Jun. 2007.

[2] P. Balducci, J. Roop, L. Schienbein, J. DeSteese, and M. Weimar, "Electrical power interruption cost estimates for individual industries, sectors, and US economy," U.S. Dept. of Energy, Tech. Rep., 2002.

[3] R. Cossent, T. Gómez, and P. Frías, "Towards a future with large penetration of distributed generation: Is the current regulation of electricity distribution ready? regulatory recommendations under a european perspective," *Energy Policy*, vol. 37, no. 3, pp. 1145–1155, March 2009.

[4] P. L. Joskow, "Lessons learned from electricity market liberalization," *The Energy Journal*, vol. 29, no. Special I, pp. 9–42, 2008.

[5] C. Marnay and M. Venkataramanan, "Microgrids in the evolving electricity generation and delivery infrastructure," in *IEEE Power Engineering Society General Meeting*, 2006.

[6] A. B. Lovins, E. K. Datta, T. Feiler, K. R. Rabago, J. N. Swisher, A. Lehmann, and K. Wicker, *Small is profitable: the hidden economic benefits of making electrical resources the right size*. Rocky Mountain Institute, 2002.

[7] V. Vaitheeswaran, *Power to the People*. Earthscan, 2005.

[8] Z. Wang, A. Scaglione, and R. J. Thomas, "Generating Statistically Correct Random Topologies for Testing Smart Grid Communication and Control Networks," *IEEE Transactions on Smart Grid*, vol. 1, no. 1, pp. 28–39, Jun. 2010.

[9] M. Anghel, K. A. Werley, and A. E. Motter, "Stochastic model for power grid dynamics," *Hawaii International Conference on System Sciences*, vol. 0, p. 113, 2007.

[10] B. Carreras, V. Lynch, M. Sachtjen, I. Dobson, and D. Newman, "Modeling blackout dynamics in power transmission networks with simple structure," in *HICSS '01: Proceedings of the 34th Annual Hawaii International Conference on System Sciences (HICSS-34)-Volume 2*. IEEE Computer Society, 2001, p. 2018.

[11] I. A. Hiskens and M. Akke, "Analysis of the nordel power grid disturbance of january 1, 1997 using trajectory sensitivities," *IEEE Transactions on Power Systems*, vol. 14, no. 3, Aug 1999.

[12] D. P. Chassin and C. Posse, "Evaluating North American electric grid reliability using the Barabási Albert network model," *Physica A Statistical Mechanics and its Applications*, vol. 355, pp. 667–677, Sep. 2005.

[13] R. Albert, I. Albert, and G. L. Nakarado, "Structural vulnerability of the North American Power Grid," *Phys. Rev. E*, vol. 69, no. 2, p. 025103, Feb 2004.

[14] P. Crucitti, V. Latora, and M. Marchiori, "A topological analysis of the italian electric power grid," *Physica A: Statistical Mechanics and its Applications*, vol. 338, no. 1-2, pp. 92 – 97, 2004, proceedings of the conference A Nonlinear World: the Real World, 2nd International Conference on Frontier Science.

[15] A. J. Holmgren, "Using Graph Models to Analyze the Vulnerability of Electric Power Networks," *Risk Analysis*, vol. 26, no. 4, pp. 955–969, August 2006.

[16] M. Rosas-Casals, S. Valverde, and R. V. Solé, "Topological vulnerability of the European power grid under errors and attacks," *International Journal of Bifurcation and Chaos*, vol. 17, no. 07, p. 2465, 2007.

[17] M. Rosas-Casals and B. Corominas-Murtra, "Assessing European power grid reliability by means of topological measures," Working Paper, June 2009.

[18] P. Crucitti, V. Latora, and M. Marchiori, "Model for cascading failures in complex networks," *Physical Review E*, vol. 69, no. 4, pp. 3–6, 2004.

[19] V. Rosato, S. Bologna, and F. Tiriticco, "Topological properties of high-voltage electrical transmission network s," *Electric Power Systems Research*, vol. 77, no. 2, pp. 99–105, 2007.

[20] P. Crucitti, V. Latora, and M. Marchiori, "Locating critical lines in high-voltage electrical power grids," *Fluctuation and Noise Letters*, vol. 5, no. 2, pp. L201–L208, 2005.

[21] D. J. Watts and S. H. Strogatz, "Collective dynamics of 'small-world' networks," *Nature*, vol. 393, no. 6684, pp. 440–442, June 1998.

[22] S. H. Strogatz, "Exploring complex networks." *Nature*, vol. 410, no. 6825, pp. 268–76, March 2001.

[23] P. Erdős and A. Rényi, "On random graphs. I," *Publ. Math. Debrecen*, vol. 6, pp. 290–297, 1959.

[24] D. J. Watts, *Small Worlds: The Dynamics of Networks between Order and Randomness*. Princeton, NJ, USA: Princeton University Press, 2003.

[25] A. L. Barabási, "Linked: The new science of networks," *American Journal of Physics*, vol. 71, no. 4, pp. 409–410, 2004.

[26] A. L. Barabási, R. Albert, and H. Jeong, "Scale-free characteristics of random networks: the topology of the World Wide Web," *Physica A: Statistical Mechanics and its Applications*, vol. 281, no. 1-4, pp. 69–77, June 2000.

[27] A. L. Barabási, "Scale-free networks: a decade and beyond." *Science*, vol. 325, no. 5939, pp. 412–3, 2009.

[28] R. Albert, H. Jeong, and A. L. Barabási, "Error and attack tolerance of complex networks," *Nature*, vol. 406, no. 6794, pp. 378–382, Jul. 2000.

[29] A. L. Barabási and R. Albert, "Emergence of scaling in random networks," *Science*, vol. 286, no. 5439, p. 509, 1999.

[30] W. Aiello, F. Chung, and L. Lu, "Random evolution in massive graphs," in *Handbook of massive data sets*, J. Abello, P. M. Pardalos, and M. G. C. Resende, Eds. Norwell, MA, USA: Kluwer Academic Publishers, 2002, pp. 97–122.

[31] Y. Moreno, R. Pastor-Satorras, A. Vazquez, and A. Vespignani, "Critical load and congestion instabilities in scale-free networks," *Europhysics Letters*, vol. 62, 2003.

[32] L. A. N. Amaral, A. Scala, M. Barthélémy, and H. E. Stanley, "Classes of small-world networks," *Proceedings of the National Academy of Sciences of the United States of America*, vol. 97, no. 21, pp. 11 149–11 152, October 2000.

[33] M. E. J. Newman, "Mathematics of networks," in *The New Palgrave Dictionary of Economics*, S. N. Durlauf and L. E. Blume, Eds. Palgrave Macmillan, 2008.

[34] P. Bonacich, "Some unique properties of eigenvector centrality," *Social Networks*, vol. 29, no. 4, pp. 555–564, Oct. 2007.

[35] R. Cohen, K. Erez, D. Ben-Avraham, and S. Havlin, "Resilience of the internet to random breakdowns," *Physical review letters*, vol. 85, no. 21, pp. 4626–8, Nov. 2000.

[36] B. Mohar, "Laplace eigenvalues of graphs a survey," *Discrete Mathematics*, vol. 109, no. 1-3, pp. 171–183, Nov. 1992.

[37] ——, "The Laplacian spectrum of graphs," *Graph theory, combinatorics, and applications*, vol. 2, pp. 871–898, 1991.

[38] M. E. J. Newman, "Analysis of weighted networks," *Phys. Rev. E*, vol. 70, no. 5, p. 056131, Nov 2004.

[39] F. Leuthold, H. Weigt, and C. von Hirschhausen, "Efficient pricing for european electricity networks - the theory of nodal pricing applied to feeding-in wind in germany," *Utilities Policy*, vol. 16, no. 4, pp. 284 – 291, 2008, european Regulatory Perspectives.

[40] P. Sotkiewicz and J. Vignolo, "Nodal Pricing for Distribution Networks: Efficient Pricing for Efficiency Enhancing DG," *IEEE Transactions on Power Systems*, vol. 21, no. 2, pp. 1013–1014, May 2006.

[41] P. Chiradeja, "Benefit of Distributed Generation: A Line Loss Reduction Analysis," *2005 IEEE/PES Transmission & Distribution Conference & Exposition: Asia and Pacific*, pp. 1–5, 2005.

[42] T. Khoa, P. Binh, and H. Tran, "Optimizing Location and Sizing of Distributed Generation in Distribution Systems," *2006 IEEE PES Power Systems Conference and Exposition*, pp. 725–732, 2006.

[43] A. D. Le, M. Kashem, M. Negnevitsky, and G. Ledwich, "Optimal Distributed Generation Parameters for Reducing Losses with Economic Consideration," *2007 IEEE Power Engineering Society General Meeting*, pp. 1–8, Jun. 2007.

[44] C. Harris, *Electricity Markets: Pricing, Structures and Economics.* Wiley, 2006.

[45] M. Munasinghe, "Engineering-economic analysis of electric power systems," *Proceedings of the IEEE*, vol. 72, no. 4, pp. 424 – 461, apr. 1984.

[46] R. Albert, I. Albert, and G. Nakarado, "Structural vulnerability of the north american power grid," *Physical Review E*, vol. 69, 2004.

[47] R. V. Solé, M. Rosas-Casals, B. Corominas-Murtra, and S. Valverde, "Robustness of the European power grids under intentional attack," *Physical Review E*, vol. 77, no. 2, pp. 1–7, Feb. 2008.

[48] M. E. J. Newman, "The Structure and Function of Complex Networks," *SIAM Review*, vol. 45, no. 2, p. 167, 2003.

[49] A. L. Barabási, R. Albert, and H. Jeong, "Mean-field theory for scale-free random networks," *Physica A: Statistical Mechanics and its Applications*, vol. 272, no. 1-2, pp. 173–187, Oct. 1999.